

## **TITLE V INSPECTION PHOTO REQUIREMENTS AS OF 08/06/2012**

Per the unanimous vote of the Pembroke Board of Health at the August 6, 2012 meeting, all Title 5 inspections reports MUST include the following photos:

1. Before T-5 begins prior to digging.
2. Septic tank with measuring stick in place in the tank showing the fluid levels.
3. Zabel filter.
4. Inlet T.
5. D-box in place -- level and sound.
6. T-5 after completion with everything closed.

Photos may be on paper or snap shots. Please notate address and date of each photo. No exceptions.

If you are unable to print out the photos, you may email them to:

[lcullity@townofpembrokemass.org](mailto:lcullity@townofpembrokemass.org)

and cc to:

[slandy@townofpembrokemass.org](mailto:slandy@townofpembrokemass.org)

Include the address and the date of the photos.